

## **Lead Mitigation Plan – Update # 10**

Date: May 1, 2017

### **Schools Awaiting Northern Health Approval for Resumption of Normal Operations Following Lead Mitigation Work:**

Nukko Lake Elementary

### **Schools with Successful Lead Mitigation - Returned to Normal Operations:**

See Lead Mitigation - April Results (Highlighted in Green) – Posted on Website

College Heights Secondary

Edgewood Elementary

Malaspina Elementary

Peden Hill Elementary (staff room sink)

Polaris Montessori Elementary (PAC kitchen sink)

Vanway Elementary (PAC kitchen sink and one drinking fountain)

All other locations must continue to be flushed if used for drinking purposes.

### **Work in Progress**

#### **Foothills Elementary:**

Galvanized pipe has been identified at Foothills Elementary. It will be replaced in May 2017. Re-testing of water will occur. Should the results not meet established guidelines, new faucets and drinking fountains with lead filters will be installed.

#### **Heritage Elementary:**

Work will commence the week April 24, 2017 to replace faucets and drinking fountains. Water will be re-tested. Should the results not meet established guidelines, lead filters will be installed.

#### **Pineview Elementary:**

A new faucet and lead filter will be installed at the location which failed to meet established guidelines. Re-testing of water will occur. Work should take place by first week of May 2017.

#### **Nusdeh Yoh Elementary:**

Pipe will be replaced in the school and then the school water will be re-tested. If results do not fall within the acceptable range, lead filters will be installed along with new drinking fountains and other approved potable water locations. Schedule to be determined by contractor however, this work is expected to take place during the summer months, 2017.

## **Planning Stage:**

Planning and materials are being ordered to replace the drinking fountains at these facilities with planned completion into the fall of 2017.

Beaverly Elementary (fountains)  
College Heights Elementary (fountain)  
Peden Hill Elementary (fountain)  
Pinewood Elementary (fountain)  
Polaris Elementary (fountains)  
Vanway Elementary (fountains)  
Westwood Elementary (fountains)

SD57 will update progress as work is completed.

## **Present Operations:**

Northern Health procedures for flushing must continue and be logged for the following schools until further notice:

Beaverly Elementary  
College Heights Elementary  
College Heights Secondary  
Foothills Elementary  
Heritage Elementary  
John McInnis Centre  
Malaspina Elementary  
Nukko Lake Elementary  
Nusdeh Yoh Elementary  
Peden hill Elementary  
Pineview Elementary  
Pinewood Elementary  
Polaris Montessori Elementary  
Vanway Elementary  
Westwood Elementary

In schools that have numerous fountains where tested levels of lead in the water were in excess of acceptable levels, fountains may have been disabled. Water dispensing coolers along with bottled water have been provided.