

Results of Water Quality Testing in School District No. 57 (Prince George) Schools/Facilities:

RESULTS OF APRIL 2017 WATER QUALITY LEAD TESTING

Maximum Allowable Concentration (MAC)

Guideline for Canadian Drinking Water .01 mg/l

SCHOOL or Facility Name	Testing March 2017				Testing April 2017			
	# SAMPLES TAKEN/SCHOOL	# SAMPLES OVER MAC	SAMPLE LOCATION	Range of Lead mg/l	SAMPLE LOCATION	Lead PF	Lead Flushed	
COLLEGE HEIGHTS SECONDARY	42	1	S11	0.000139 to 0.0252	S11	0.00556	0.000985	
MALASPINA ELEMENTARY	12	1	S2	0.000134 to 0.0252	S2	0.00218	0.000022	
PEDEN HILL ELEMENTARY	10	2	F2	0.000179 to .0154				
			S2		S2	0.00314	0.000052	
POLARIS MONTESSORI ELEMENTARY	12	3	S1	0.000229 to 0.0243	S1	0.00337	0.000033	
			F2					
			F3					
VANWAY ELEMENTARY	18	3	S2	0.000170 to 0.227	S2	0.00402	0.000046	
			F6		F6			0.000656