

Results of Water Quality Testing in School District No.57 (Prince George) Schools and Facilities:**RETESTING NO.1 REPORT DATED AUGUST 12, 2016:**

School or Facility Name	Range of Lead mg/l	Exceedances
Nusdeh Yoh Elementary	.0001 to .0643	2 out of 6
Kool Kats Daycare	.0008 to .0086	0 out of 6
Flushing no longer required approved by Northern Health		
Heritage Elementary	.0020 to .0060	0 out of 6
One location that tested positively before was not retested therefore flushing continues		
Foothills Elementary	.0038 to .0157	3 out of 6
Nukko Lake Elementary	.0005 to .1420	2 out of 6
Edgewood Elementary	.0041 to .0202	2 out of 6
Pineview Elementary	.0007 to .0160	1 out of 6
Guideline for Canadian Drinking Water	0.01	
Schools have been notified to not use the drinking fountains and bottled water is being provided.		
Flushing is to continue until further remediation has occurred.		