

**Results of Water Quality Testing in School District No. 57 (Prince George)
Schools and Facilities:**

SUMMARY FROM ENGINEERING REPORT DATED JUNE 29, 2016

School or Facility Name	Range of Lead mg/l	Exceedances
Austin Road Elementary	.0042 to .0043	0 out of 2
Beaverly Elementary	.0025 to .0036	0 out of 2
Blackburn Elementary	.0017 to .0031	0 out of 2
Buckhorn Elementary	.0005 to .0015	0 out of 2
Centre for Healthy Living	.0007 to .0008	0 out of 2
College Heights Elementary	.0014 to .0016	0 out of 2
College Heights Secondary	.0009 to .0098	0 out of 2
DP Todd Secondary	.0020 to .0030	0 out of 2
Duchess Park Secondary	.0001 to .0015	0 out of 2
Lac des Bois Elementary	.0021 to .0039	0 out of 2
Edgewood Elementary	.0073 to .0135	1 out of 2
Foothills Elementary	.0109 to .0199	2 out of 2
Giscome Elementary	.0003 to .0021	0 out of 2
Glenview Elementary	.0044 to .0077	0 out of 2
Hart highlands Elementary	.0034 to .0056	0 out of 2
Harwin Elementary	.0019 to .0037	0 out of 2
Heather Park Elementary	.0009 to .0020	0 out of 2
Heritage Elementary	.0015 to .0282	1 out of 2
Highland	.0019 to .0067	0 out of 2
Hixon Elementary	.0003 to .0007	0 out of 2
John McInnis Ctr.	.0028 to .0036	0 out of 2
Kelly Road Secondary	.0035 to .0082	0 out of 2
Kool Kats Daycare	.0060 to .0146	1 out of 2
Mackenzie Secondary	.0018 to .0042	0 out of 2
Malaspina Elementary	.0025 to .0030	0 out of 2
McBride Elementary	.0003 to .0004	0 out of 2
McBride Secondary	.0005 to .0010	0 out of 2
Morfee Elementary	.0006 to .0008	0 out of 2
Nukko Lake Elementary	.0056 to .0483	1 out of 2
Nusdeh Yoh Elementary	.0006 to .0115	1 out of 2
Peden Hill Elementary	.0019 to .0036	0 out of 2
PGYSA	.0021 to .0063	0 out of 2
Pineview Elementary	.0009 to .0174	1 out of 2
Pinewood Elementary	.0026 to .0035	0 out of 2
Polaris Montessori Elementary	.0021 to .0063	0 out of 2
Rocky Mtn. Rangers	.0066 to .0094	0 out of 2
Prince George Secondary	.0013 to .0032	0 out of 2
Quinson Elementary	.0010 to .0018	0 out of 2
Ron Brent Elementary	.0006 to .0015	0 out of 2
School District	.0008 to .0015	0 out of 2
South Fort George Family Resource Ctr.	.0008 to .0014	0 out of 2
Southridge Elementary	.0009 to .0015	0 out of 2
Spruceland Traditional Elementary	.0038 to .0042	0 out of 2
Valemount Elementary	.0026 to .0033	0 out of 2
Valemount Secondary	.0002 to .0006	0 out of 2
Van Bien Elementary	.0021 to .0039	0 out of 2
Vanway Elementary	.0033 to .0082	0 out of 2
Westwood Elementary	.0011 to .0040	0 out of 2
Guideline for Canadian Drinking Water	0.01	

Following these results, a daily flushing program was instituted as indicated by Northern Health.