

# VENTILATION SYSTEM OVERVIEW

This template has been developed to support school districts in sharing information on ventilation systems at the school level. This includes information on how systems meet requirements for regular inspection and maintenance, and additional mitigations that have been put in place to promote student and staff safety throughout the pandemic.

<b>School District:</b>	57 - Prince George
<b>School Name:</b>	Beaverly Elementary
<b>REQUIREMENT:</b> Regular inspection and maintenance of HVAC systems	Yes/No: Yes
	Date of last inspection: 2021-08-25
	Date of next inspection: 2021-09-24
	Date and type of most recent maintenance: Aug 25 2021 Filter change/Visual Inspection
<b>RECOMMENDATION:</b> Increase supply of outside air	Yes/No: Yes
	Detail: Providing the maximum amount of outside air to improve ventilation.
<b>RECOMMENDATION:</b> Upgrade filtration, including installing MERV-13 filters, where possible	Yes/No: No
	Detail (Including filter grade):  MERV 8
<b>RECOMMENDATION:</b> Use other air cleaning or treatment technologies	Yes/No: No
	Detail:
<b>RECOMMENDATION:</b> Manage energy use and air distribution through building automation control systems	Yes/No: Yes
	Detail: This school district operates a very robust DDC system.
<b>Other Relevant Information:</b>	
<b>District Contact for any Questions:</b>	Name: Brett Apolzczer
	Phone Number: 250-561-6810
	Email: bapolzczer@sd57.bc.ca

# VENTILATION SYSTEM OVERVIEW

This template has been developed to support school districts in sharing information on ventilation systems at the school level. This includes information on how systems meet requirements for regular inspection and maintenance, and additional mitigations that have been put in place to promote student and staff safety throughout the pandemic.

<b>School District:</b>	57 - Prince George
<b>School Name:</b>	Blackburn Elementary
<b>REQUIREMENT:</b> Regular inspection and maintenance of HVAC systems	Yes/No: Yes
	Date of last inspection: 2021-09-02
	Date of next inspection: 2021-09-24
	Date and type of most recent maintenance: Sept 2 2021 Filter change/Visual Inspection
<b>RECOMMENDATION:</b> Increase supply of outside air	Yes/No: Yes
	Detail: Providing the maximum amount of outside air to improve ventilation.
<b>RECOMMENDATION:</b> Upgrade filtration, including installing MERV-13 filters, where possible	Yes/No: No
	Detail (Including filter grade):  MERV 8
<b>RECOMMENDATION:</b> Use other air cleaning or treatment technologies	Yes/No: No
	Detail:
<b>RECOMMENDATION:</b> Manage energy use and air distribution through building automation control systems	Yes/No: Yes
	Detail: This school district operates a very robust DDC system.
<b>Other Relevant Information:</b>	
<b>District Contact for any Questions:</b>	Name: Brett Apolzczer
	Phone Number: 250-561-6810
	Email: bapolzczer@sd57.bc.ca

# VENTILATION SYSTEM OVERVIEW

This template has been developed to support school districts in sharing information on ventilation systems at the school level. This includes information on how systems meet requirements for regular inspection and maintenance, and additional mitigations that have been put in place to promote student and staff safety throughout the pandemic.

<b>School District:</b>	57 - Prince George
<b>School Name:</b>	Buckhorn Elementary
<b>REQUIREMENT:</b> Regular inspection and maintenance of HVAC systems	Yes/No: Yes
	Date of last inspection: 2021-09-08
	Date of next inspection: 2021-09-24
	Date and type of most recent maintenance: Sept 8 2021 Filter change/Visual Inspection
<b>RECOMMENDATION:</b> Increase supply of outside air	Yes/No: Yes
	Detail: Providing the maximum amount of outside air to improve ventilation.
<b>RECOMMENDATION:</b> Upgrade filtration, including installing MERV-13 filters, where possible	Yes/No: No
	Detail (Including filter grade):  MERV 8
<b>RECOMMENDATION:</b> Use other air cleaning or treatment technologies	Yes/No: No
	Detail:
<b>RECOMMENDATION:</b> Manage energy use and air distribution through building automation control systems	Yes/No: Yes
	Detail: This school district operates a very robust DDC system.
<b>Other Relevant Information:</b>	
<b>District Contact for any Questions:</b>	Name: Brett Apolczer
	Phone Number: 250-561-6810
	Email: bapolczer@sd57.bc.ca

# VENTILATION SYSTEM OVERVIEW

This template has been developed to support school districts in sharing information on ventilation systems at the school level. This includes information on how systems meet requirements for regular inspection and maintenance, and additional mitigations that have been put in place to promote student and staff safety throughout the pandemic.

<b>School District:</b>	57 - Prince George
<b>School Name:</b>	CAO
<b>REQUIREMENT:</b> Regular inspection and maintenance of HVAC systems	Yes/No: Yes
	Date of last inspection: 2021-09-10
	Date of next inspection: 2021-09-30
	Date and type of most recent maintenance: Sept 10 2021 Filter change/Visual Inspection
<b>RECOMMENDATION:</b> Increase supply of outside air	Yes/No: Yes
	Detail: Providing the maximum amount of outside air to improve ventilation.
<b>RECOMMENDATION:</b> Upgrade filtration, including installing MERV-13 filters, where possible	Yes/No: No
	Detail (Including filter grade):  MERV 8
<b>RECOMMENDATION:</b> Use other air cleaning or treatment technologies	Yes/No: No
	Detail:
<b>RECOMMENDATION:</b> Manage energy use and air distribution through building automation control systems	Yes/No: Yes
	Detail: This school district operates a very robust DDC system.
<b>Other Relevant Information:</b>	
<b>District Contact for any Questions:</b>	Name: Brett Apolzcer
	Phone Number: 250-561-6810
	Email: bapolzcer@sd57.bc.ca

# VENTILATION SYSTEM OVERVIEW

This template has been developed to support school districts in sharing information on ventilation systems at the school level. This includes information on how systems meet requirements for regular inspection and maintenance, and additional mitigations that have been put in place to promote student and staff safety throughout the pandemic.

<b>School District:</b>	57 - Prince George
<b>School Name:</b>	College Heights Elementary
<b>REQUIREMENT:</b> Regular inspection and maintenance of HVAC systems	Yes/No: Yes
	Date of last inspection: 2021-08-27
	Date of next inspection: 2021-09-24
	Date and type of most recent maintenance: Aug 27 2021 Filter change/Visual Inspection
<b>RECOMMENDATION:</b> Increase supply of outside air	Yes/No: Yes
	Detail: Providing the maximum amount of outside air to improve ventilation.
<b>RECOMMENDATION:</b> Upgrade filtration, including installing MERV-13 filters, where possible	Yes/No: No
	Detail (Including filter grade):  MERV 8
<b>RECOMMENDATION:</b> Use other air cleaning or treatment technologies	Yes/No: No
	Detail:
<b>RECOMMENDATION:</b> Manage energy use and air distribution through building automation control systems	Yes/No: Yes
	Detail: This school district operates a very robust DDC system.
<b>Other Relevant Information:</b>	
<b>District Contact for any Questions:</b>	Name: Brett Apolzczer
	Phone Number: 250-561-6810
	Email: bapolzczer@sd57.bc.ca

# VENTILATION SYSTEM OVERVIEW

This template has been developed to support school districts in sharing information on ventilation systems at the school level. This includes information on how systems meet requirements for regular inspection and maintenance, and additional mitigations that have been put in place to promote student and staff safety throughout the pandemic.

<b>School District:</b>	57 - Prince George
<b>School Name:</b>	College Heights Secondary School
<b>REQUIREMENT:</b> Regular inspection and maintenance of HVAC systems	Yes/No: Yes
	Date of last inspection: 2021-09-02
	Date of next inspection: 2021-09-24
	Date and type of most recent maintenance: Sept 2 2021 Filter change/Visual Inspection
<b>RECOMMENDATION:</b> Increase supply of outside air	Yes/No: Yes
	Detail: Providing the maximum amount of outside air to improve ventilation.
<b>RECOMMENDATION:</b> Upgrade filtration, including installing MERV-13 filters, where possible	Yes/No: No
	Detail (Including filter grade):  MERV 8
<b>RECOMMENDATION:</b> Use other air cleaning or treatment technologies	Yes/No: No
	Detail:
<b>RECOMMENDATION:</b> Manage energy use and air distribution through building automation control systems	Yes/No: Yes
	Detail: This school district operates a very robust DDC system.
<b>Other Relevant Information:</b>	
<b>District Contact for any Questions:</b>	Name: Brett Apolczer
	Phone Number: 250-561-6810
	Email: bapolczer@sd57.bc.ca

# VENTILATION SYSTEM OVERVIEW

This template has been developed to support school districts in sharing information on ventilation systems at the school level. This includes information on how systems meet requirements for regular inspection and maintenance, and additional mitigations that have been put in place to promote student and staff safety throughout the pandemic.

<b>School District:</b>	57 - Prince George
<b>School Name:</b>	DP Todd Secondary
<b>REQUIREMENT:</b> Regular inspection and maintenance of HVAC systems	Yes/No: Yes
	Date of last inspection: 2021-08-30
	Date of next inspection: 2021-09-17
	Date and type of most recent maintenance: Aug 30 2021 Filter change/Visual Inspection
<b>RECOMMENDATION:</b> Increase supply of outside air	Yes/No: Yes
	Detail: Providing the maximum amount of outside air to improve ventilation.
<b>RECOMMENDATION:</b> Upgrade filtration, including installing MERV-13 filters, where possible	Yes/No: No
	Detail (Including filter grade):  MERV 8
<b>RECOMMENDATION:</b> Use other air cleaning or treatment technologies	Yes/No: No
	Detail:
<b>RECOMMENDATION:</b> Manage energy use and air distribution through building automation control systems	Yes/No: Yes
	Detail: This school district operates a very robust DDC system.
<b>Other Relevant Information:</b>	
<b>District Contact for any Questions:</b>	Name: Brett Apolzczer
	Phone Number: 250-561-6810
	Email: bapolzczer@sd57.bc.ca

# VENTILATION SYSTEM OVERVIEW

This template has been developed to support school districts in sharing information on ventilation systems at the school level. This includes information on how systems meet requirements for regular inspection and maintenance, and additional mitigations that have been put in place to promote student and staff safety throughout the pandemic.

<b>School District:</b>	57 - Prince George
<b>School Name:</b>	Duchess Park Secondary
<b>REQUIREMENT:</b> Regular inspection and maintenance of HVAC systems	Yes/No: Yes
	Date of last inspection: 2021-09-09
	Date of next inspection: 2021-09-24
	Date and type of most recent maintenance: Sept 9 2021 Filter change/Visual Inspection
<b>RECOMMENDATION:</b> Increase supply of outside air	Yes/No: Yes
	Detail: Providing the maximum amount of outside air to improve ventilation.
<b>RECOMMENDATION:</b> Upgrade filtration, including installing MERV-13 filters, where possible	Yes/No: No
	Detail (Including filter grade):  MERV 8
<b>RECOMMENDATION:</b> Use other air cleaning or treatment technologies	Yes/No: No
	Detail:
<b>RECOMMENDATION:</b> Manage energy use and air distribution through building automation control systems	Yes/No: Yes
	Detail: This school district operates a very robust DDC system.
<b>Other Relevant Information:</b>	
<b>District Contact for any Questions:</b>	Name: Brett Apolzczer
	Phone Number: 250-561-6810
	Email: bapolzczer@sd57.bc.ca



# VENTILATION SYSTEM OVERVIEW

This template has been developed to support school districts in sharing information on ventilation systems at the school level. This includes information on how systems meet requirements for regular inspection and maintenance, and additional mitigations that have been put in place to promote student and staff safety throughout the pandemic.

<b>School District:</b>	57 - Prince George
<b>School Name:</b>	Edgewood Elementary
<b>REQUIREMENT:</b> Regular inspection and maintenance of HVAC systems	Yes/No: Yes
	Date of last inspection: 2021-08-26
	Date of next inspection: 2021-09-10
	Date and type of most recent maintenance: Aug 26 2021 Filter change/Visual Inspection
<b>RECOMMENDATION:</b> Increase supply of outside air	Yes/No: Yes
	Detail: Providing the maximum amount of outside air to improve ventilation.
<b>RECOMMENDATION:</b> Upgrade filtration, including installing MERV-13 filters, where possible	Yes/No: No
	Detail (Including filter grade):  MERV 8
<b>RECOMMENDATION:</b> Use other air cleaning or treatment technologies	Yes/No: No
	Detail:
<b>RECOMMENDATION:</b> Manage energy use and air distribution through building automation control systems	Yes/No: Yes
	Detail: This school district operates a very robust DDC system.
<b>Other Relevant Information:</b>	
<b>District Contact for any Questions:</b>	Name: Brett Apolczer
	Phone Number: 250-561-6810
	Email: bapolczer@sd57.bc.ca

# VENTILATION SYSTEM OVERVIEW

This template has been developed to support school districts in sharing information on ventilation systems at the school level. This includes information on how systems meet requirements for regular inspection and maintenance, and additional mitigations that have been put in place to promote student and staff safety throughout the pandemic.

<b>School District:</b>	57 - Prince George
<b>School Name:</b>	Foothills Elementary
<b>REQUIREMENT:</b> Regular inspection and maintenance of HVAC systems	Yes/No: Yes
	Date of last inspection: 2021-09-01
	Date of next inspection: 2021-09-17
	Date and type of most recent maintenance: Sept 1 2021 Filter change/Visual Inspection
<b>RECOMMENDATION:</b> Increase supply of outside air	Yes/No: Yes
	Detail: Providing the maximum amount of outside air to improve ventilation.
<b>RECOMMENDATION:</b> Upgrade filtration, including installing MERV-13 filters, where possible	Yes/No: No
	Detail (Including filter grade):  MERV 8
<b>RECOMMENDATION:</b> Use other air cleaning or treatment technologies	Yes/No: No
	Detail:
<b>RECOMMENDATION:</b> Manage energy use and air distribution through building automation control systems	Yes/No: Yes
	Detail: This school district operates a very robust DDC system.
<b>Other Relevant Information:</b>	
<b>District Contact for any Questions:</b>	Name: Brett Apolczer
	Phone Number: 250-561-6810
	Email: bapolczer@sd57.bc.ca

# VENTILATION SYSTEM OVERVIEW

This template has been developed to support school districts in sharing information on ventilation systems at the school level. This includes information on how systems meet requirements for regular inspection and maintenance, and additional mitigations that have been put in place to promote student and staff safety throughout the pandemic.

<b>School District:</b>	57 - Prince George
<b>School Name:</b>	Giscome Elementary
<b>REQUIREMENT:</b> Regular inspection and maintenance of HVAC systems	Yes/No: Yes
	Date of last inspection: 2021-09-02
	Date of next inspection: 2021-09-17
	Date and type of most recent maintenance: Sept 2 2021 Filter change/Visual Inspection
<b>RECOMMENDATION:</b> Increase supply of outside air	Yes/No: Yes
	Detail: Providing the maximum amount of outside air to improve ventilation.
<b>RECOMMENDATION:</b> Upgrade filtration, including installing MERV-13 filters, where possible	Yes/No: No
	Detail (Including filter grade):  MERV 8
<b>RECOMMENDATION:</b> Use other air cleaning or treatment technologies	Yes/No: No
	Detail:
<b>RECOMMENDATION:</b> Manage energy use and air distribution through building automation control systems	Yes/No: Yes
	Detail: This school district operates a very robust DDC system.
<b>Other Relevant Information:</b>	
<b>District Contact for any Questions:</b>	Name: Brett Apolzcer
	Phone Number: 250-561-6810
	Email: bapolzcer@sd57.bc.ca

# VENTILATION SYSTEM OVERVIEW

This template has been developed to support school districts in sharing information on ventilation systems at the school level. This includes information on how systems meet requirements for regular inspection and maintenance, and additional mitigations that have been put in place to promote student and staff safety throughout the pandemic.

<b>School District:</b>	57 - Prince George
<b>School Name:</b>	Glenview Elementary
<b>REQUIREMENT:</b> Regular inspection and maintenance of HVAC systems	Yes/No: Yes
	Date of last inspection: 2021-08-26
	Date of next inspection: 2021-09-10
	Date and type of most recent maintenance: Aug 26 2021 Filter change/Visual Inspection
<b>RECOMMENDATION:</b> Increase supply of outside air	Yes/No: Yes
	Detail: Providing the maximum amount of outside air to improve ventilation.
<b>RECOMMENDATION:</b> Upgrade filtration, including installing MERV-13 filters, where possible	Yes/No: No
	Detail (Including filter grade):  MERV 8
<b>RECOMMENDATION:</b> Use other air cleaning or treatment technologies	Yes/No: No
	Detail:
<b>RECOMMENDATION:</b> Manage energy use and air distribution through building automation control systems	Yes/No: Yes
	Detail: This school district operates a very robust DDC system.
<b>Other Relevant Information:</b>	
<b>District Contact for any Questions:</b>	Name: Brett Apolczer
	Phone Number: 250-561-6810
	Email: bapolczer@sd57.bc.ca

# VENTILATION SYSTEM OVERVIEW

This template has been developed to support school districts in sharing information on ventilation systems at the school level. This includes information on how systems meet requirements for regular inspection and maintenance, and additional mitigations that have been put in place to promote student and staff safety throughout the pandemic.

<b>School District:</b>	57 - Prince George
<b>School Name:</b>	Hart Highlands Elementary
<b>REQUIREMENT:</b> Regular inspection and maintenance of HVAC systems	Yes/No: Yes
	Date of last inspection: 2021-08-26
	Date of next inspection: 2021-09-10
	Date and type of most recent maintenance: Aug 26 2021 Filter change/Visual Inspection
<b>RECOMMENDATION:</b> Increase supply of outside air	Yes/No: Yes
	Detail: Providing the maximum amount of outside air to improve ventilation.
<b>RECOMMENDATION:</b> Upgrade filtration, including installing MERV-13 filters, where possible	Yes/No: No
	Detail (Including filter grade):  MERV 8
<b>RECOMMENDATION:</b> Use other air cleaning or treatment technologies	Yes/No: No
	Detail:
<b>RECOMMENDATION:</b> Manage energy use and air distribution through building automation control systems	Yes/No: Yes
	Detail: This school district operates a very robust DDC system.
<b>Other Relevant Information:</b>	
<b>District Contact for any Questions:</b>	Name: Brett Apolczer
	Phone Number: 250-561-6810
	Email: bapolczer@sd57.bc.ca

# VENTILATION SYSTEM OVERVIEW

This template has been developed to support school districts in sharing information on ventilation systems at the school level. This includes information on how systems meet requirements for regular inspection and maintenance, and additional mitigations that have been put in place to promote student and staff safety throughout the pandemic.

<b>School District:</b>	57 - Prince George
<b>School Name:</b>	Harwin Elementary
<b>REQUIREMENT:</b> Regular inspection and maintenance of HVAC systems	Yes/No: Yes
	Date of last inspection: 2021-09-01
	Date of next inspection: 2021-09-17
	Date and type of most recent maintenance: Sept 1 2021 Filter change/Visual Inspection
<b>RECOMMENDATION:</b> Increase supply of outside air	Yes/No: Yes
	Detail: Providing the maximum amount of outside air to improve ventilation.
<b>RECOMMENDATION:</b> Upgrade filtration, including installing MERV-13 filters, where possible	Yes/No: No
	Detail (Including filter grade):  MERV 8
<b>RECOMMENDATION:</b> Use other air cleaning or treatment technologies	Yes/No: No
	Detail:
<b>RECOMMENDATION:</b> Manage energy use and air distribution through building automation control systems	Yes/No: Yes
	Detail: This school district operates a very robust DDC system.
<b>Other Relevant Information:</b>	
<b>District Contact for any Questions:</b>	Name: Brett Apolzczer
	Phone Number: 250-561-6810
	Email: bapolzczer@sd57.bc.ca

# VENTILATION SYSTEM OVERVIEW

This template has been developed to support school districts in sharing information on ventilation systems at the school level. This includes information on how systems meet requirements for regular inspection and maintenance, and additional mitigations that have been put in place to promote student and staff safety throughout the pandemic.

<b>School District:</b>	57 - Prince George
<b>School Name:</b>	Heather Park Elementary
<b>REQUIREMENT:</b> Regular inspection and maintenance of HVAC systems	Yes/No: Yes
	Date of last inspection: 2021-08-31
	Date of next inspection: 2021-09-17
	Date and type of most recent maintenance: Aug 31 2021 Filter change/Visual Inspection
<b>RECOMMENDATION:</b> Increase supply of outside air	Yes/No: Yes
	Detail: Providing the maximum amount of outside air to improve ventilation.
<b>RECOMMENDATION:</b> Upgrade filtration, including installing MERV-13 filters, where possible	Yes/No: No
	Detail (Including filter grade):  MERV 8
<b>RECOMMENDATION:</b> Use other air cleaning or treatment technologies	Yes/No: No
	Detail:
<b>RECOMMENDATION:</b> Manage energy use and air distribution through building automation control systems	Yes/No: Yes
	Detail: This school district operates a very robust DDC system.
<b>Other Relevant Information:</b>	
<b>District Contact for any Questions:</b>	Name: Brett Apolzcer
	Phone Number: 250-561-6810
	Email: bapolzcer@sd57.bc.ca

# VENTILATION SYSTEM OVERVIEW

This template has been developed to support school districts in sharing information on ventilation systems at the school level. This includes information on how systems meet requirements for regular inspection and maintenance, and additional mitigations that have been put in place to promote student and staff safety throughout the pandemic.

<b>School District:</b>	57 - Prince George
<b>School Name:</b>	Heritage Elementary
<b>REQUIREMENT:</b> Regular inspection and maintenance of HVAC systems	Yes/No: Yes
	Date of last inspection: 2021-09-03
	Date of next inspection: 2021-09-24
	Date and type of most recent maintenance: Sept 3 2021 Filter change/Visual Inspection
<b>RECOMMENDATION:</b> Increase supply of outside air	Yes/No: Yes
	Detail: Providing the maximum amount of outside air to improve ventilation.
<b>RECOMMENDATION:</b> Upgrade filtration, including installing MERV-13 filters, where possible	Yes/No: No
	Detail (Including filter grade):  MERV 8
<b>RECOMMENDATION:</b> Use other air cleaning or treatment technologies	Yes/No: No
	Detail:
<b>RECOMMENDATION:</b> Manage energy use and air distribution through building automation control systems	Yes/No: Yes
	Detail: This school district operates a very robust DDC system.
<b>Other Relevant Information:</b>	
<b>District Contact for any Questions:</b>	Name: Brett Apolzczer
	Phone Number: 250-561-6810
	Email: bapolzczer@sd57.bc.ca



# VENTILATION SYSTEM OVERVIEW

This template has been developed to support school districts in sharing information on ventilation systems at the school level. This includes information on how systems meet requirements for regular inspection and maintenance, and additional mitigations that have been put in place to promote student and staff safety throughout the pandemic.

<b>School District:</b>	57 - Prince George
<b>School Name:</b>	Highland Elementary
<b>REQUIREMENT:</b> Regular inspection and maintenance of HVAC systems	Yes/No: Yes
	Date of last inspection: 2021-09-07
	Date of next inspection: 2021-09-24
	Date and type of most recent maintenance: July 22 2021 Sept 7 2021 Filter change/Visual Inspection
<b>RECOMMENDATION:</b> Increase supply of outside air	Yes/No: Yes
	Detail: Providing the maximum amount of outside air to improve ventilation.
<b>RECOMMENDATION:</b> Upgrade filtration, including installing MERV-13 filters, where possible	Yes/No: No
	Detail (Including filter grade):  MERV 8
<b>RECOMMENDATION:</b> Use other air cleaning or treatment technologies	Yes/No: No
	Detail:
<b>RECOMMENDATION:</b> Manage energy use and air distribution through building automation control systems	Yes/No: Yes
	Detail: This school district operates a very robust DDC system.
<b>Other Relevant Information:</b>	
<b>District Contact for any Questions:</b>	Name: Brett Apolzcer
	Phone Number: 250-561-6810
	Email: bapolzcer@sd57.bc.ca

# VENTILATION SYSTEM OVERVIEW

This template has been developed to support school districts in sharing information on ventilation systems at the school level. This includes information on how systems meet requirements for regular inspection and maintenance, and additional mitigations that have been put in place to promote student and staff safety throughout the pandemic.

<b>School District:</b>	57 - Prince George
<b>School Name:</b>	Hixon Elementary
<b>REQUIREMENT:</b> Regular inspection and maintenance of HVAC systems	Yes/No: Yes
	Date of last inspection: 2021-08-31
	Date of next inspection: 2021-09-17
	Date and type of most recent maintenance: Filter change/Visual Inspection Aug 31 2021
<b>RECOMMENDATION:</b> Increase supply of outside air	Yes/No: Yes
	Detail: Providing the maximum amount of outside air to improve ventilation.
<b>RECOMMENDATION:</b> Upgrade filtration, including installing MERV-13 filters, where possible	Yes/No: No
	Detail (Including filter grade):  MERV 8
<b>RECOMMENDATION:</b> Use other air cleaning or treatment technologies	Yes/No: No
	Detail:
<b>RECOMMENDATION:</b> Manage energy use and air distribution through building automation control systems	Yes/No: Yes
	Detail: This school district operates a very robust DDC system.
<b>Other Relevant Information:</b>	
<b>District Contact for any Questions:</b>	Name: Brett Apolczer
	Phone Number: 250-561-6810
	Email: bapolczer@sd57.bc.ca

# VENTILATION SYSTEM OVERVIEW

This template has been developed to support school districts in sharing information on ventilation systems at the school level. This includes information on how systems meet requirements for regular inspection and maintenance, and additional mitigations that have been put in place to promote student and staff safety throughout the pandemic.

<b>School District:</b>	57 - Prince George
<b>School Name:</b>	John McInnis
<b>REQUIREMENT:</b> Regular inspection and maintenance of HVAC systems	Yes/No: Yes
	Date of last inspection: 2021-08-30
	Date of next inspection: 2021-09-24
	Date and type of most recent maintenance: Aug 30 2021 Filter change/Visual Inspection
<b>RECOMMENDATION:</b> Increase supply of outside air	Yes/No: Yes
	Detail: Providing the maximum amount of outside air to improve ventilation.
<b>RECOMMENDATION:</b> Upgrade filtration, including installing MERV-13 filters, where possible	Yes/No: No
	Detail (Including filter grade):  MERV 8
<b>RECOMMENDATION:</b> Use other air cleaning or treatment technologies	Yes/No: No
	Detail:
<b>RECOMMENDATION:</b> Manage energy use and air distribution through building automation control systems	Yes/No: Yes
	Detail: This school district operates a very robust DDC system.
<b>Other Relevant Information:</b>	
<b>District Contact for any Questions:</b>	Name: Brett Apolzcer
	Phone Number: 250-561-6810
	Email: bapolzcer@sd57.bc.ca

# VENTILATION SYSTEM OVERVIEW

This template has been developed to support school districts in sharing information on ventilation systems at the school level. This includes information on how systems meet requirements for regular inspection and maintenance, and additional mitigations that have been put in place to promote student and staff safety throughout the pandemic.

<b>School District:</b>	57 - Prince George
<b>School Name:</b>	Lac des Bois
<b>REQUIREMENT:</b> Regular inspection and maintenance of HVAC systems	Yes/No: Yes
	Date of last inspection: 2021-08-31
	Date of next inspection: 2021-09-17
	Date and type of most recent maintenance: Aug 31 2021 Filter change/Visual Inspection
<b>RECOMMENDATION:</b> Increase supply of outside air	Yes/No: Yes
	Detail: Providing the maximum amount of outside air to improve ventilation.
<b>RECOMMENDATION:</b> Upgrade filtration, including installing MERV-13 filters, where possible	Yes/No: No
	Detail (Including filter grade):  MERV 8
<b>RECOMMENDATION:</b> Use other air cleaning or treatment technologies	Yes/No: No
	Detail:
<b>RECOMMENDATION:</b> Manage energy use and air distribution through building automation control systems	Yes/No: Yes
	Detail: This school district operates a very robust DDC system.
<b>Other Relevant Information:</b>	
<b>District Contact for any Questions:</b>	Name: Brett Apolczer
	Phone Number: 250-561-6810
	Email: bapolczer@sd57.bc.ca

# VENTILATION SYSTEM OVERVIEW

This template has been developed to support school districts in sharing information on ventilation systems at the school level. This includes information on how systems meet requirements for regular inspection and maintenance, and additional mitigations that have been put in place to promote student and staff safety throughout the pandemic.

<b>School District:</b>	57 - Prince George
<b>School Name:</b>	Mackenzie Secondary
<b>REQUIREMENT:</b> Regular inspection and maintenance of HVAC systems	Yes/No: Yes
	Date of last inspection: 2021-09-02
	Date of next inspection: 2021-09-24
	Date and type of most recent maintenance: Sept 2 2021 Filter change/Visual Inspection
<b>RECOMMENDATION:</b> Increase supply of outside air	Yes/No: Yes
	Detail: Providing the maximum amount of outside air to improve ventilation.
<b>RECOMMENDATION:</b> Upgrade filtration, including installing MERV-13 filters, where possible	Yes/No: No
	Detail (Including filter grade):  MERV 8
<b>RECOMMENDATION:</b> Use other air cleaning or treatment technologies	Yes/No: No
	Detail:
<b>RECOMMENDATION:</b> Manage energy use and air distribution through building automation control systems	Yes/No: Yes
	Detail: This school district operates a very robust DDC system.
<b>Other Relevant Information:</b>	
<b>District Contact for any Questions:</b>	Name: Brett Apolczer
	Phone Number: 250-561-6810
	Email: bapolczer@sd57.bc.ca

# VENTILATION SYSTEM OVERVIEW

This template has been developed to support school districts in sharing information on ventilation systems at the school level. This includes information on how systems meet requirements for regular inspection and maintenance, and additional mitigations that have been put in place to promote student and staff safety throughout the pandemic.

<b>School District:</b>	57 - Prince George
<b>School Name:</b>	Malaspina Elementary
<b>REQUIREMENT:</b> Regular inspection and maintenance of HVAC systems	Yes/No: Yes
	Date of last inspection: 2021-08-31
	Date of next inspection: 2021-09-24
	Date and type of most recent maintenance: Filter change/Visual Inspection Aug 11 2021
<b>RECOMMENDATION:</b> Increase supply of outside air	Yes/No: Yes
	Detail: Providing the maximum amount of outside air to improve ventilation.
<b>RECOMMENDATION:</b> Upgrade filtration, including installing MERV-13 filters, where possible	Yes/No: No
	Detail (Including filter grade):  MERV 8
<b>RECOMMENDATION:</b> Use other air cleaning or treatment technologies	Yes/No: No
	Detail:
<b>RECOMMENDATION:</b> Manage energy use and air distribution through building automation control systems	Yes/No: Yes
	Detail: This school district operates a very robust DDC system.
<b>Other Relevant Information:</b>	
<b>District Contact for any Questions:</b>	Name: Brett Apolzczer
	Phone Number: 250-561-6810
	Email: bapolzczer@sd57.bc.ca

# VENTILATION SYSTEM OVERVIEW

This template has been developed to support school districts in sharing information on ventilation systems at the school level. This includes information on how systems meet requirements for regular inspection and maintenance, and additional mitigations that have been put in place to promote student and staff safety throughout the pandemic.

<b>School District:</b>	57 - Prince George
<b>School Name:</b>	McBride Centennial
<b>REQUIREMENT:</b> Regular inspection and maintenance of HVAC systems	Yes/No: Yes
	Date of last inspection: 2021-09-03
	Date of next inspection: 2021-09-17
	Date and type of most recent maintenance: Sept 3 2021 Filter change/Visual Inspection
<b>RECOMMENDATION:</b> Increase supply of outside air	Yes/No: Yes
	Detail: Providing the maximum amount of outside air to improve ventilation.
<b>RECOMMENDATION:</b> Upgrade filtration, including installing MERV-13 filters, where possible	Yes/No: No
	Detail (Including filter grade):  MERV 8
<b>RECOMMENDATION:</b> Use other air cleaning or treatment technologies	Yes/No: No
	Detail:
<b>RECOMMENDATION:</b> Manage energy use and air distribution through building automation control systems	Yes/No: Yes
	Detail: This school district operates a very robust DDC system.
<b>Other Relevant Information:</b>	
<b>District Contact for any Questions:</b>	Name: Brett Apolzczer
	Phone Number: 250-561-6810
	Email: bapolzczer@sd57.bc.ca

# VENTILATION SYSTEM OVERVIEW

This template has been developed to support school districts in sharing information on ventilation systems at the school level. This includes information on how systems meet requirements for regular inspection and maintenance, and additional mitigations that have been put in place to promote student and staff safety throughout the pandemic.

<b>School District:</b>	57 - Prince George
<b>School Name:</b>	McBride Secondary
<b>REQUIREMENT:</b> Regular inspection and maintenance of HVAC systems	Yes/No: Yes
	Date of last inspection: 2021-09-03
	Date of next inspection: 2021-09-17
	Date and type of most recent maintenance: Sept 3 2021 Filter change/Visual Inspection
<b>RECOMMENDATION:</b> Increase supply of outside air	Yes/No: Yes
	Detail: Providing the maximum amount of outside air to improve ventilation.
<b>RECOMMENDATION:</b> Upgrade filtration, including installing MERV-13 filters, where possible	Yes/No: No
	Detail (Including filter grade):  MERV 8
<b>RECOMMENDATION:</b> Use other air cleaning or treatment technologies	Yes/No: No
	Detail:
<b>RECOMMENDATION:</b> Manage energy use and air distribution through building automation control systems	Yes/No: Yes
	Detail: This school district operates a very robust DDC system.
<b>Other Relevant Information:</b>	
<b>District Contact for any Questions:</b>	Name: Brett Apolzcer
	Phone Number: 250-561-6810
	Email: bapolzcer@sd57.bc.ca



# VENTILATION SYSTEM OVERVIEW

This template has been developed to support school districts in sharing information on ventilation systems at the school level. This includes information on how systems meet requirements for regular inspection and maintenance, and additional mitigations that have been put in place to promote student and staff safety throughout the pandemic.

<b>School District:</b>	57 - Prince George
<b>School Name:</b>	Morfee Elementary
<b>REQUIREMENT:</b> Regular inspection and maintenance of HVAC systems	Yes/No: Yes
	Date of last inspection: 2021-09-01
	Date of next inspection: 2021-09-09
	Date and type of most recent maintenance: Sept 1 2021 Filter change/Visual Inspection
<b>RECOMMENDATION:</b> Increase supply of outside air	Yes/No: Yes
	Detail: Providing the maximum amount of outside air to improve ventilation.
<b>RECOMMENDATION:</b> Upgrade filtration, including installing MERV-13 filters, where possible	Yes/No: No
	Detail (Including filter grade):  MERV 8
<b>RECOMMENDATION:</b> Use other air cleaning or treatment technologies	Yes/No: No
	Detail:
<b>RECOMMENDATION:</b> Manage energy use and air distribution through building automation control systems	Yes/No: Yes
	Detail: This school district operates a very robust DDC system.
<b>Other Relevant Information:</b>	
<b>District Contact for any Questions:</b>	Name: Brett Apolczer
	Phone Number: 250-561-6810
	Email: bapolczer@sd57.bc.ca

# VENTILATION SYSTEM OVERVIEW

This template has been developed to support school districts in sharing information on ventilation systems at the school level. This includes information on how systems meet requirements for regular inspection and maintenance, and additional mitigations that have been put in place to promote student and staff safety throughout the pandemic.

<b>School District:</b>	57 - Prince George
<b>School Name:</b>	Nukko Lake Elementary
<b>REQUIREMENT:</b> Regular inspection and maintenance of HVAC systems	Yes/No: Yes
	Date of last inspection: 2021-08-31
	Date of next inspection: 2021-09-17
	Date and type of most recent maintenance: Aug 31 2021 Filter change/Visual Inspection
<b>RECOMMENDATION:</b> Increase supply of outside air	Yes/No: Yes
	Detail: Providing the maximum amount of outside air to improve ventilation.
<b>RECOMMENDATION:</b> Upgrade filtration, including installing MERV-13 filters, where possible	Yes/No: No
	Detail (Including filter grade):  MERV 8
<b>RECOMMENDATION:</b> Use other air cleaning or treatment technologies	Yes/No: No
	Detail:
<b>RECOMMENDATION:</b> Manage energy use and air distribution through building automation control systems	Yes/No: Yes
	Detail: This school district operates a very robust DDC system.
<b>Other Relevant Information:</b>	
<b>District Contact for any Questions:</b>	Name: Brett Apolzcer
	Phone Number: 250-561-6810
	Email: bapolzcer@sd57.bc.ca

# VENTILATION SYSTEM OVERVIEW

This template has been developed to support school districts in sharing information on ventilation systems at the school level. This includes information on how systems meet requirements for regular inspection and maintenance, and additional mitigations that have been put in place to promote student and staff safety throughout the pandemic.

<b>School District:</b>	57 - Prince George
<b>School Name:</b>	Nusdeh Yoh Elementary
<b>Sept 2</b>	Yes/No: Yes
	Date of last inspection: 2021-09-02
	Date of next inspection: 2021-09-20
	Date and type of most recent maintenance: Sept 2 2021 Filter change/Visual Inspection
<b>RECOMMENDATION:</b> Increase supply of outside air	Yes/No: Yes
	Detail: Providing the maximum amount of outside air to improve ventilation.
<b>RECOMMENDATION:</b> Upgrade filtration, including installing MERV-13 filters, where possible	Yes/No: No
	Detail (Including filter grade):  MERV 8
<b>RECOMMENDATION:</b> Use other air cleaning or treatment technologies	Yes/No: No
	Detail:
<b>RECOMMENDATION:</b> Manage energy use and air distribution through building automation control systems	Yes/No: Yes
	Detail: This school district operates a very robust DDC system.
<b>Other Relevant Information:</b>	
<b>District Contact for any Questions:</b>	Name: Brett Apolczer
	Phone Number: 250-561-6810
	Email: bapolczer@sd57.bc.ca

# VENTILATION SYSTEM OVERVIEW

This template has been developed to support school districts in sharing information on ventilation systems at the school level. This includes information on how systems meet requirements for regular inspection and maintenance, and additional mitigations that have been put in place to promote student and staff safety throughout the pandemic.

<b>School District:</b>	57 - Prince George
<b>School Name:</b>	Peden Hill Elementary
<b>Sept 2</b>	Yes/No: Yes
	Date of last inspection: 2021-08-25
	Date of next inspection: 2021-09-23
	Date and type of most recent maintenance: Aug 25 2021 Filter change/Visual Inspection
<b>RECOMMENDATION:</b> Increase supply of outside air	Yes/No: Yes
	Detail: Providing the maximum amount of outside air to improve ventilation.
<b>RECOMMENDATION:</b> Upgrade filtration, including installing MERV-13 filters, where possible	Yes/No: No
	Detail (Including filter grade):  MERV 8
<b>RECOMMENDATION:</b> Use other air cleaning or treatment technologies	Yes/No: No
	Detail:
<b>RECOMMENDATION:</b> Manage energy use and air distribution through building automation control systems	Yes/No: Yes
	Detail: This school district operates a very robust DDC system.
<b>Other Relevant Information:</b>	
<b>District Contact for any Questions:</b>	Name: Brett Apolczer
	Phone Number: 250-561-6810
	Email: bapolczer@sd57.bc.ca

# VENTILATION SYSTEM OVERVIEW

This template has been developed to support school districts in sharing information on ventilation systems at the school level. This includes information on how systems meet requirements for regular inspection and maintenance, and additional mitigations that have been put in place to promote student and staff safety throughout the pandemic.

<b>School District:</b>	57 - Prince George
<b>School Name:</b>	Prince George Senior Secondary
<b>Sept 2</b>	Yes/No: Yes
	Date of last inspection: 2021-09-02
	Date of next inspection: 2021-09-24
	Date and type of most recent maintenance: Sept 2 2021 Filter change/Visual Inspection
<b>RECOMMENDATION:</b> Increase supply of outside air	Yes/No: Yes
	Detail: Providing the maximum amount of outside air to improve ventilation.
<b>RECOMMENDATION:</b> Upgrade filtration, including installing MERV-13 filters, where possible	Yes/No: No
	Detail (Including filter grade):  MERV 8
<b>RECOMMENDATION:</b> Use other air cleaning or treatment technologies	Yes/No: No
	Detail:
<b>RECOMMENDATION:</b> Manage energy use and air distribution through building automation control systems	Yes/No: Yes
	Detail: This school district operates a very robust DDC system.
<b>Other Relevant Information:</b>	
<b>District Contact for any Questions:</b>	Name: Brett Apolzcer
	Phone Number: 250-561-6810
	Email: bapolzcer@sd57.bc.ca

# VENTILATION SYSTEM OVERVIEW

This template has been developed to support school districts in sharing information on ventilation systems at the school level. This includes information on how systems meet requirements for regular inspection and maintenance, and additional mitigations that have been put in place to promote student and staff safety throughout the pandemic.

<b>School District:</b>	57 - Prince George
<b>School Name:</b>	PGYSA
<b>Sept 2</b>	Yes/No: Yes
	Date of last inspection: 2021-09-09
	Date of next inspection: 2021-09-24
	Date and type of most recent maintenance: Sept 9 2021 Filter Change/Visual Inspection
<b>RECOMMENDATION:</b> Increase supply of outside air	Yes/No: Yes
	Detail: Providing the maximum amount of outside air to improve ventilation.
<b>RECOMMENDATION:</b> Upgrade filtration, including installing MERV-13 filters, where possible	Yes/No: No
	Detail (Including filter grade):  MERV 8
<b>RECOMMENDATION:</b> Use other air cleaning or treatment technologies	Yes/No: No
	Detail:
<b>RECOMMENDATION:</b> Manage energy use and air distribution through building automation control systems	Yes/No: Yes
	Detail: This school district operates a very robust DDC system.
<b>Other Relevant Information:</b>	
<b>District Contact for any Questions:</b>	Name: Brett Apolczer
	Phone Number: 250-561-6810
	Email: bapolczer@sd57.bc.ca

# VENTILATION SYSTEM OVERVIEW

This template has been developed to support school districts in sharing information on ventilation systems at the school level. This includes information on how systems meet requirements for regular inspection and maintenance, and additional mitigations that have been put in place to promote student and staff safety throughout the pandemic.

<b>School District:</b>	57 - Prince George
<b>School Name:</b>	Pineview Elementary
<b>Sept 2</b>	Yes/No: Yes
	Date of last inspection: 2021-09-03
	Date of next inspection: 2021-09-17
	Date and type of most recent maintenance: Sept 3 2021 Filter change/Visual Inspection
<b>RECOMMENDATION:</b> Increase supply of outside air	Yes/No: Yes
	Detail: Providing the maximum amount of outside air to improve ventilation.
<b>RECOMMENDATION:</b> Upgrade filtration, including installing MERV-13 filters, where possible	Yes/No: No
	Detail (Including filter grade):  MERV 8
<b>RECOMMENDATION:</b> Use other air cleaning or treatment technologies	Yes/No: No
	Detail:
<b>RECOMMENDATION:</b> Manage energy use and air distribution through building automation control systems	Yes/No: Yes
	Detail: This school district operates a very robust DDC system.
<b>Other Relevant Information:</b>	
<b>District Contact for any Questions:</b>	Name: Brett Apolczer
	Phone Number: 250-561-6810
	Email: bapolczer@sd57.bc.ca

# VENTILATION SYSTEM OVERVIEW

This template has been developed to support school districts in sharing information on ventilation systems at the school level. This includes information on how systems meet requirements for regular inspection and maintenance, and additional mitigations that have been put in place to promote student and staff safety throughout the pandemic.

<b>School District:</b>	57 - Prince George
<b>School Name:</b>	Pinewood Elementary
<b>Sept 2</b>	Yes/No: Yes
	Date of last inspection: 2021-08-24
	Date of next inspection: 2021-09-10
	Date and type of most recent maintenance: Aug 24 2021 Filter change/Visual Inspection
<b>RECOMMENDATION:</b> Increase supply of outside air	Yes/No: Yes
	Detail: Providing the maximum amount of outside air to improve ventilation.
<b>RECOMMENDATION:</b> Upgrade filtration, including installing MERV-13 filters, where possible	Yes/No: No
	Detail (Including filter grade):  MERV 8
<b>RECOMMENDATION:</b> Use other air cleaning or treatment technologies	Yes/No: No
	Detail:
<b>RECOMMENDATION:</b> Manage energy use and air distribution through building automation control systems	Yes/No: Yes
	Detail: This school district operates a very robust DDC system.
<b>Other Relevant Information:</b>	
<b>District Contact for any Questions:</b>	Name: Brett Apolczer
	Phone Number: 250-561-6810
	Email: bapolczer@sd57.bc.ca



# VENTILATION SYSTEM OVERVIEW

This template has been developed to support school districts in sharing information on ventilation systems at the school level. This includes information on how systems meet requirements for regular inspection and maintenance, and additional mitigations that have been put in place to promote student and staff safety throughout the pandemic.

<b>School District:</b>	57 - Prince George
<b>School Name:</b>	Polaris Elementary
<b>Sept 2</b>	Yes/No: Yes
	Date of last inspection: 2021-09-01
	Date of next inspection: 2021-09-24
	Date and type of most recent maintenance: Sept 1 2021 Filter change/Visual Inspection
<b>RECOMMENDATION:</b> Increase supply of outside air	Yes/No: Yes
	Detail: Providing the maximum amount of outside air to improve ventilation.
<b>RECOMMENDATION:</b> Upgrade filtration, including installing MERV-13 filters, where possible	Yes/No: No
	Detail (Including filter grade):  MERV 8
<b>RECOMMENDATION:</b> Use other air cleaning or treatment technologies	Yes/No: No
	Detail:
<b>RECOMMENDATION:</b> Manage energy use and air distribution through building automation control systems	Yes/No: Yes
	Detail: This school district operates a very robust DDC system.
<b>Other Relevant Information:</b>	
<b>District Contact for any Questions:</b>	Name: Brett Apolzczer
	Phone Number: 250-561-6810
	Email: bapolzczer@sd57.bc.ca

# VENTILATION SYSTEM OVERVIEW

This template has been developed to support school districts in sharing information on ventilation systems at the school level. This includes information on how systems meet requirements for regular inspection and maintenance, and additional mitigations that have been put in place to promote student and staff safety throughout the pandemic.

<b>School District:</b>	57 - Prince George
<b>School Name:</b>	Quinson Elementary
<b>Sept 2</b>	Yes/No: Yes
	Date of last inspection: 2021-09-02
	Date of next inspection: 2021-09-24
	Date and type of most recent maintenance: Sept 2 2021 Filter change/Visual Inspection
<b>RECOMMENDATION:</b> Increase supply of outside air	Yes/No: Yes
	Detail: Providing the maximum amount of outside air to improve ventilation.
<b>RECOMMENDATION:</b> Upgrade filtration, including installing MERV-13 filters, where possible	Yes/No: No
	Detail (Including filter grade):  MERV 8
<b>RECOMMENDATION:</b> Use other air cleaning or treatment technologies	Yes/No: No
	Detail:
<b>RECOMMENDATION:</b> Manage energy use and air distribution through building automation control systems	Yes/No: Yes
	Detail: This school district operates a very robust DDC system.
<b>Other Relevant Information:</b>	
<b>District Contact for any Questions:</b>	Name: Brett Apolczer
	Phone Number: 250-561-6810
	Email: bapolczer@sd57.bc.ca

# VENTILATION SYSTEM OVERVIEW

This template has been developed to support school districts in sharing information on ventilation systems at the school level. This includes information on how systems meet requirements for regular inspection and maintenance, and additional mitigations that have been put in place to promote student and staff safety throughout the pandemic.

<b>School District:</b>	57 - Prince George
<b>School Name:</b>	Ron Brent Elementary
<b>Sept 2</b>	Yes/No: Yes
	Date of last inspection: 2021-09-08
	Date of next inspection: 2021-09-24
	Date and type of most recent maintenance: Sept 8 2021 Filter change/Visual Inspection
<b>RECOMMENDATION:</b> Increase supply of outside air	Yes/No: Yes
	Detail: Providing the maximum amount of outside air to improve ventilation.
<b>RECOMMENDATION:</b> Upgrade filtration, including installing MERV-13 filters, where possible	Yes/No: No
	Detail (Including filter grade):  MERV 8
<b>RECOMMENDATION:</b> Use other air cleaning or treatment technologies	Yes/No: No
	Detail:
<b>RECOMMENDATION:</b> Manage energy use and air distribution through building automation control systems	Yes/No: Yes
	Detail: This school district operates a very robust DDC system.
<b>Other Relevant Information:</b>	
<b>District Contact for any Questions:</b>	Name: Brett Apolzcer
	Phone Number: 250-561-6810
	Email: bapolzcer@sd57.bc.ca

# VENTILATION SYSTEM OVERVIEW

This template has been developed to support school districts in sharing information on ventilation systems at the school level. This includes information on how systems meet requirements for regular inspection and maintenance, and additional mitigations that have been put in place to promote student and staff safety throughout the pandemic.

<b>School District:</b>	57 - Prince George
<b>School Name:</b>	Shas Ti Kelly Road Secondary
<b>Sept 2</b>	Yes/No: Yes
	Date of last inspection: 2021-08-26
	Date of next inspection: 2021-09-17
	Date and type of most recent maintenance: Sept 8 2021 Replaced Limit switches on rooftop air handler
<b>RECOMMENDATION:</b> Increase supply of outside air	Yes/No: Yes
	Detail: Providing the maximum amount of outside air to improve ventilation.
<b>RECOMMENDATION:</b> Upgrade filtration, including installing MERV-13 filters, where possible	Yes/No: No
	Detail (Including filter grade):  MERV 8
<b>RECOMMENDATION:</b> Use other air cleaning or treatment technologies	Yes/No: No
	Detail:
<b>RECOMMENDATION:</b> Manage energy use and air distribution through building automation control systems	Yes/No: Yes
	Detail: This school district operates a very robust DDC system.
<b>Other Relevant Information:</b>	
<b>District Contact for any Questions:</b>	Name: Brett Apolzczer
	Phone Number: 250-561-6810
	Email: bapolzczer@sd57.bc.ca

# VENTILATION SYSTEM OVERVIEW

This template has been developed to support school districts in sharing information on ventilation systems at the school level. This includes information on how systems meet requirements for regular inspection and maintenance, and additional mitigations that have been put in place to promote student and staff safety throughout the pandemic.

<b>School District:</b>	57 - Prince George
<b>School Name:</b>	South Ft. George
<b>Sept 2</b>	Yes/No: Yes
	Date of last inspection: 2021-09-09
	Date of next inspection: 2021-09-24
	Date and type of most recent maintenance: Sept 9 2021 Filter Change/Visual Inspection
<b>RECOMMENDATION:</b> Increase supply of outside air	Yes/No: Yes
	Detail: Providing the maximum amount of outside air to improve ventilation.
<b>RECOMMENDATION:</b> Upgrade filtration, including installing MERV-13 filters, where possible	Yes/No: No
	Detail (Including filter grade):  MERV 8
<b>RECOMMENDATION:</b> Use other air cleaning or treatment technologies	Yes/No: No
	Detail:
<b>RECOMMENDATION:</b> Manage energy use and air distribution through building automation control systems	Yes/No: Yes
	Detail: This school district operates a very robust DDC system.
<b>Other Relevant Information:</b>	
<b>District Contact for any Questions:</b>	Name: Brett Apolzczer
	Phone Number: 250-561-6810
	Email: bapolzczer@sd57.bc.ca

# VENTILATION SYSTEM OVERVIEW

This template has been developed to support school districts in sharing information on ventilation systems at the school level. This includes information on how systems meet requirements for regular inspection and maintenance, and additional mitigations that have been put in place to promote student and staff safety throughout the pandemic.

<b>School District:</b>	57 - Prince George
<b>School Name:</b>	Southridge Elementary
<b>Sept 2</b>	Yes/No: Yes
	Date of last inspection: 2021-08-25
	Date of next inspection: 2021-09-24
	Date and type of most recent maintenance: Aug 25 2021 Filter Change/Visual Inspection
<b>RECOMMENDATION:</b> Increase supply of outside air	Yes/No: Yes
	Detail: Providing the maximum amount of outside air to improve ventilation.
<b>RECOMMENDATION:</b> Upgrade filtration, including installing MERV-13 filters, where possible	Yes/No: No
	Detail (Including filter grade):  MERV 8
<b>RECOMMENDATION:</b> Use other air cleaning or treatment technologies	Yes/No: No
	Detail:
<b>RECOMMENDATION:</b> Manage energy use and air distribution through building automation control systems	Yes/No: Yes
	Detail: This school district operates a very robust DDC system.
<b>Other Relevant Information:</b>	
<b>District Contact for any Questions:</b>	Name: Brett Apolczer
	Phone Number: 250-561-6810
	Email: bapolczer@sd57.bc.ca

# VENTILATION SYSTEM OVERVIEW

This template has been developed to support school districts in sharing information on ventilation systems at the school level. This includes information on how systems meet requirements for regular inspection and maintenance, and additional mitigations that have been put in place to promote student and staff safety throughout the pandemic.

<b>School District:</b>	57 - Prince George
<b>School Name:</b>	Springwood Elementary
<b>Sept 2</b>	Yes/No: Yes
	Date of last inspection: 2021-08-03
	Date of next inspection: 2021-09-17
	Date and type of most recent maintenance: Aug 31 2021 Filter Change/Visual Inspection
<b>RECOMMENDATION:</b> Increase supply of outside air	Yes/No: Yes
	Detail: Providing the maximum amount of outside air to improve ventilation.
<b>RECOMMENDATION:</b> Upgrade filtration, including installing MERV-13 filters, where possible	Yes/No: No
	Detail (Including filter grade):  MERV 8
<b>RECOMMENDATION:</b> Use other air cleaning or treatment technologies	Yes/No: No
	Detail:
<b>RECOMMENDATION:</b> Manage energy use and air distribution through building automation control systems	Yes/No: Yes
	Detail: This school district operates a very robust DDC system.
<b>Other Relevant Information:</b>	
<b>District Contact for any Questions:</b>	Name: Brett Apolzczer
	Phone Number: 250-561-6810
	Email: bapolzczer@sd57.bc.ca

# VENTILATION SYSTEM OVERVIEW

This template has been developed to support school districts in sharing information on ventilation systems at the school level. This includes information on how systems meet requirements for regular inspection and maintenance, and additional mitigations that have been put in place to promote student and staff safety throughout the pandemic.

<b>School District:</b>	57 - Prince George
<b>School Name:</b>	Spruceland Elementary
<b>Sept 2</b>	Yes/No: Yes
	Date of last inspection: 2021-08-31
	Date of next inspection: 2021-09-17
	Date and type of most recent maintenance: Aug 31 2021 Filter Change/Visual Inspection
<b>RECOMMENDATION:</b> Increase supply of outside air	Yes/No: Yes
	Detail: Providing the maximum amount of outside air to improve ventilation.
<b>RECOMMENDATION:</b> Upgrade filtration, including installing MERV-13 filters, where possible	Yes/No: No
	Detail (Including filter grade):  MERV 8
<b>RECOMMENDATION:</b> Use other air cleaning or treatment technologies	Yes/No: No
	Detail:
<b>RECOMMENDATION:</b> Manage energy use and air distribution through building automation control systems	Yes/No: Yes
	Detail: This school district operates a very robust DDC system.
<b>Other Relevant Information:</b>	
<b>District Contact for any Questions:</b>	Name: Brett Apolzcer
	Phone Number: 250-561-6810
	Email: bapolzcer@sd57.bc.ca



# VENTILATION SYSTEM OVERVIEW

This template has been developed to support school districts in sharing information on ventilation systems at the school level. This includes information on how systems meet requirements for regular inspection and maintenance, and additional mitigations that have been put in place to promote student and staff safety throughout the pandemic.

<b>School District:</b>	57 - Prince George
<b>School Name:</b>	Valemount Elementary
<b>RY</b>	Yes/No: Yes
	Date of last inspection: 2021-06-14
	Date of next inspection: 2021-09-15
	Date and type of most recent maintenance: March 11 2021 Filter Change/Visual Inspection
<b>RECOMMENDATION:</b> Increase supply of outside air	Yes/No: Yes
	Detail: Providing the maximum amount of outside air to improve ventilation.
<b>RECOMMENDATION:</b> Upgrade filtration, including installing MERV-13 filters, where possible	Yes/No: No
	Detail (Including filter grade):  MERV 8
<b>RECOMMENDATION:</b> Use other air cleaning or treatment technologies	Yes/No: No
	Detail:
<b>RECOMMENDATION:</b> Manage energy use and air distribution through building automation control systems	Yes/No: Yes
	Detail: This school district operates a very robust DDC system.
<b>Other Relevant Information:</b>	
<b>District Contact for any Questions:</b>	Name: Brett Apolczer
	Phone Number: 250-561-6810
	Email: bapolczer@sd57.bc.ca

# VENTILATION SYSTEM OVERVIEW

This template has been developed to support school districts in sharing information on ventilation systems at the school level. This includes information on how systems meet requirements for regular inspection and maintenance, and additional mitigations that have been put in place to promote student and staff safety throughout the pandemic.

<b>School District:</b>	57 - Prince George
<b>School Name:</b>	Valemount Secondary
<b>Sept 2</b>	Yes/No: Yes
	Date of last inspection: 2021-06-14
	Date of next inspection: 2021-09-15
	Date and type of most recent maintenance: March 11 2021 Filter Change/Visual Inspection
<b>RECOMMENDATION:</b> Increase supply of outside air	Yes/No: Yes
	Detail: Providing the maximum amount of outside air to improve ventilation.
<b>RECOMMENDATION:</b> Upgrade filtration, including installing MERV-13 filters, where possible	Yes/No: No
	Detail (Including filter grade):  MERV 8
<b>RECOMMENDATION:</b> Use other air cleaning or treatment technologies	Yes/No: No
	Detail:
<b>RECOMMENDATION:</b> Manage energy use and air distribution through building automation control systems	Yes/No: Yes
	Detail: This school district operates a very robust DDC system.
<b>Other Relevant Information:</b>	
<b>District Contact for any Questions:</b>	Name: Brett Apolczer
	Phone Number: 250-561-6810
	Email: bapolczer@sd57.bc.ca

# VENTILATION SYSTEM OVERVIEW

This template has been developed to support school districts in sharing information on ventilation systems at the school level. This includes information on how systems meet requirements for regular inspection and maintenance, and additional mitigations that have been put in place to promote student and staff safety throughout the pandemic.

<b>School District:</b>	57 - Prince George
<b>School Name:</b>	Van Bien Elementary
<b>Sept 2</b>	Yes/No: Yes
	Date of last inspection: 2021-09-09
	Date of next inspection: 2021-09-24
	Date and type of most recent maintenance: Sept 9 2021 Filter Change/Visual Inspection
<b>RECOMMENDATION:</b> Increase supply of outside air	Yes/No: Yes
	Detail: Providing the maximum amount of outside air to improve ventilation.
<b>RECOMMENDATION:</b> Upgrade filtration, including installing MERV-13 filters, where possible	Yes/No: No
	Detail (Including filter grade):  MERV 8
<b>RECOMMENDATION:</b> Use other air cleaning or treatment technologies	Yes/No: No
	Detail:
<b>RECOMMENDATION:</b> Manage energy use and air distribution through building automation control systems	Yes/No: Yes
	Detail: This school district operates a very robust DDC system.
<b>Other Relevant Information:</b>	
<b>District Contact for any Questions:</b>	Name: Brett Apolzcer
	Phone Number: 250-561-6810
	Email: bapolzcer@sd57.bc.ca

# VENTILATION SYSTEM OVERVIEW

This template has been developed to support school districts in sharing information on ventilation systems at the school level. This includes information on how systems meet requirements for regular inspection and maintenance, and additional mitigations that have been put in place to promote student and staff safety throughout the pandemic.

<b>School District:</b>	57 - Prince George
<b>School Name:</b>	Vanway Elementary
<b>Sept 2</b>	Yes/No: Yes
	Date of last inspection: 2021-09-01
	Date of next inspection: 2021-09-24
	Date and type of most recent maintenance: Sept 1 2021 Filter Change/Visual Inspection
<b>RECOMMENDATION:</b> Increase supply of outside air	Yes/No: Yes
	Detail: Providing the maximum amount of outside air to improve ventilation.
<b>RECOMMENDATION:</b> Upgrade filtration, including installing MERV-13 filters, where possible	Yes/No: No
	Detail (Including filter grade):  MERV 8
<b>RECOMMENDATION:</b> Use other air cleaning or treatment technologies	Yes/No: No
	Detail:
<b>RECOMMENDATION:</b> Manage energy use and air distribution through building automation control systems	Yes/No: Yes
	Detail: This school district operates a very robust DDC system.
<b>Other Relevant Information:</b>	
<b>District Contact for any Questions:</b>	Name: Brett Apolczer
	Phone Number: 250-561-6810
	Email: bapolczer@sd57.bc.ca

# VENTILATION SYSTEM OVERVIEW

This template has been developed to support school districts in sharing information on ventilation systems at the school level. This includes information on how systems meet requirements for regular inspection and maintenance, and additional mitigations that have been put in place to promote student and staff safety throughout the pandemic.

<b>School District:</b>	57 - Prince George
<b>School Name:</b>	Westwood Elementary
<b>Sept 2</b>	Yes/No: Yes
	Date of last inspection: 2021-08-25
	Date of next inspection: 2021-09-10
	Date and type of most recent maintenance: Aug 25 2021 Filter Change/Visual Inspection
<b>RECOMMENDATION:</b> Increase supply of outside air	Yes/No: Yes
	Detail: Providing the maximum amount of outside air to improve ventilation.
<b>RECOMMENDATION:</b> Upgrade filtration, including installing MERV-13 filters, where possible	Yes/No: No
	Detail (Including filter grade):  MERV 8
<b>RECOMMENDATION:</b> Use other air cleaning or treatment technologies	Yes/No: No
	Detail:
<b>RECOMMENDATION:</b> Manage energy use and air distribution through building automation control systems	Yes/No: Yes
	Detail: This school district operates a very robust DDC system.
<b>Other Relevant Information:</b>	
<b>District Contact for any Questions:</b>	Name: Brett Apolczer
	Phone Number: 250-561-6810
	Email: bapolczer@sd57.bc.ca