



## SCHOOL DISTRICT NO. 57 (PRINCE GEORGE)

---

2100 Ferry Avenue, Prince George, B.C. V2L 4R5

Phone: (250) 561-6800 • Fax (250) 561-6801  
www.sd57.bc.ca

Date: November 23, 2016

Lead Mitigation Plan – Update # 5

Summary - Edgewood Elementary

We have received the results of the water testing conducted pre filter and post filter and submitted them to Northern Health.

The results indicated we no longer are above the permitted lead level in drinking water and as a result Northern Health has approved our request to once again operate fountains and other approved filtered drinking water sources.

Facility Services Staff will make the locations operable and the water coolers will be removed.

We have requested from Northern Health language for signage at locations which are not approved drinking water sources.

Going Forward

We will now address Nukko Lake Elementary and perform testing and follow the same process until we resolve the issue.

We will provide additional updates as we have more information to share.

Schools that must continue flushing until further notice:

Foothills Elementary

Heritage Elementary

Nukko Lake Elementary

Nusdeh Yoh Elementary

Pineview Elementary,

In these schools the fountains have been disabled and water dispensing coolers along with bottled water are being provided.

CC: Northern Health

Results of Water quality Testing in SD57 (Prince George) schools/facilities

**RETESTING NO.2 REPORT DATED 22 November 2016**

School or Facility Name	Results	
Edgewood Elementary	Pre Filter	Filter
120 Fountain	0.0134	0.000158
151 Fountain	0.00723	0.000265
Concession sink	0.0483	0.00053
Staff room sink	0.0649	0.000666
Gym fountain	0.0356	0.00953
Guideline for Canadian Drinking Water	0.01	